

Accessibility Progress Plan (updated June 2015)

Schedule D-Completed Items

Site	Date Issue Identified	Accessibility Issue	Recommended Action	Completion Date
Baltimore Recreation Centre (New Bldg)	2006	No DDDP signs	Install signs for each space	2010
Baltimore Recreation Centre (New Bldg)	2006	Inside steps, no colour contrast	Install colour contrast at edge	2009
Bewdley Community Centre	2003	Inaccessible entrance doors	Defer to Renovation	2010
	2003	Washrooms Inaccessible Heavy door Toilets too low Urinals – no grab bars Narrow doorways – 29” Doorknobs unsuitable Towel dispenser too low Men’s stall small	Defer to Renovation	2010
	2003	Limited visibility of ice pad for persons in wheelchair	Defer to Renovation	2010

Accessibility Progress Plan (updated June 2015)

Site	Date Issue Identified	Accessibility Issue	Recommended Action	Completion Date
	2005	DDDP parking spaces too narrow	Widen DDDP spaces	2010
Cold Springs Hall	2006	Outside Steps, no colour contrast	Paint strip at edge of each step	2010
Cold Springs Hall	2003	Downstairs Accessible washroom-toilet too low	Install new toilets	2009
Cold Springs Hall	2005	No DPPP parking	Install 2 signs, ramp, at back door	2012
Cold Springs Hall	2003	2 washroom signs incorrect	Install large signs on wall beside door	2009
Gores Landing Dock	2005	No DPPP parking	Arrange for designated parking area and erect signs	2012
Tax Bills	2003	Bill difficult to read One format only	Enlarge print/Make available in alternate formats-Staff has been trained to deal with this issue	2009
Transportation	2003	No accessible public transportation	Investigate transportation for persons with disabilities	2010

Accessibility Progress Plan (updated June 2015)

Site	Date Issue Identified	Accessibility Issue	Recommended Action	Completion Date
Signs	2003	Some signs not of universal design	Upgrade all signs in buildings with International Symbols.	2009
Baltimore Park	2003	Washrooms – mirror too high	Lower mirror in Washroom	2012
Baltimore Park	2003	Washrooms -soap dispenser too high -men's tissue on wrong wall	Lower dispenser Move toilet tissue to beside toilet	2012
Bewdley Waterfront Park	2008	Washrooms-low toilets Ramps to docks	Purchase when replacement required Improve access	2010 2011
	2006	Benches too high-foot area worn out	Fill with chips and dust	2010
Bewdley Community Centre Park	2003	Gate not accessible at ball diamond	Change gate on Lake Street at Main Street. Guideline-36 inch width maximum for wheelchairs. 2010-Locked gate to prevent vandalism. Gate will be opened as required	2010 Subject to review in 2015 by Committee regarding access barrier.
Plainville Park	2006	Path at gate not level	Flatten with chips and dust	2010

Accessibility Progress Plan (updated June 2015)

Site	Date Issue Identified	Accessibility Issue	Recommended Action	Completion Date
Plainville Tennis Courts	2005	No Path to court area	Install path at south easterly end of flat area in order to access gate	2010
Behan Optimist Park	2003	Playground upgrade		2013
Bewdley Park	2003	Playground upgrade		2013